



To: Mountain Regional Water Administrative Control Board Members  
From: Brian Davenport  
Date: November 2024  
Re: Operations Department Update

\*\*\*\*\*

### **OVERVIEW OF PAST MONTH**

1. We had 2 leak repairs this past month. One was on a lateral in Silver Summit. We replaced the line and installed a new meter pit. The other was in Silver Springs. We also replaced the lateral and installed a new meter pit.
2. The Lost Canyon 24" mainline valve was installed by a contractor that was hired. This valve was installed to keep customers in service if we need to shutdown and do repairs at Lost Canyon. (See pic)
3. Lost Canyon staff and Weber Basin installed a new screen at the intake structure on the Weber River. It required taking the roof off for the installation. (See pic)
4. Crews have been checking all PRV sites and conducting maintenance as needed. There are about 80 sites or so to check.
5. Old Ranch pump station upgrades are continuing. Working on connecting pipework to the tank.
6. Jailhouse electrical repairs are complete.
7. Hidden Creek flow valve upgrades were completed.

### **FOCUS FOR NEXT MONTH:**

1. Evaluations
2. Pump house maintenance and housekeeping.
3. Well facility maintenance and house keeping.

