



To: Mountain Regional Water Administrative Control Board Members
From: Brian Davenport
Date: October 2024
Re: Operations Department Update

OVERVIEW OF PAST MONTH

1. We had 3 leak repairs this past month. 2 of the repairs were in Summit Park where we repaired an old repair band aid that failed and we also repaired a lateral to a home. We repaired a valve that was leaking in the Preserve.
2. Sun Peak Well 2 was installed and is up and running. The motor went bad and was covered under warranty.
3. Summit Park well 7 failed after a power outage. The drive went bad. A new one was installed within a few days and is back up and running.
4. Working on replacing the electrical line at the Jailhouse well. It was damaged during the County upgrade project.
5. Paving and fencing at Silver Creek pump station is complete. (See pic)
6. Old Ranch pump station upgrades are continuing. Working on connecting pipework to the tank. Nitrogen tank enclosure was built by staff.

FOCUS FOR NEXT MONTH:

1. Jailhouse well repairs.
2. Winter preparations.
3. Hidden Creek valve upgrades.

